

CERTIFICATION OF ELEVATION

105A-054

DATE: October 27, 1987

NAME OF PROPERTY OWNER: James & Cindy Stayton

ADDRESS OF PROPERTY...: Lot 54, (orig.) Harrietts Bluff Village S/D

G.M.D.#.....: 31st

FLOOD ZONE.....: A12 (FIRM Panel 130262 0385B)

Required lowest finished floor elevation 13.00 feet MSL.

(If V Zone, required elevation of the bottom of the lowest
horizontal structural member: (n/a) feet MSL.)

Actual lowest floor elevation: 15.15 feet MSL.

Ground elevation at TBM: 11.78 feet MSL.

Ground elevation at Fill Area: 12.18 feet MSL.



LEONARD E. HENRY, R.L.S.

Henry and Associates

Post Office Box 1246

Kingsland, GA 31548

State of Georgia,

Registration No. 1842

Reference Work Order # 00451 & 00488.